



Organization for Security and
Co-operation in Europe

Date: 24 April 2015

ITB/SEC/06/2015

**Supply and installation of geo-thermal equipment for greenhouse heating in Uzbekistan
Clarification Note 2**

The Organization for Security and Co-operation in Europe has received requests for clarification from potential bidders on Monday, April 20, 2015 1:25 PM with regard to Invitation to Bid No. ITB/SEC/06/2015. The OSCE would like to provide the following clarifications:

Q1: What fuel you prefer to use for the heating brenner – diesel, gas or other...

A1: The question is unclear. If it means the liquid to transfer the heat from the ground to heat exchanger, then it is specific liquid as described in the terms of reference. In case if the question is about liquid to transfer the heat to the greenhouse from heat exchanger then it is normal water.

Q2: The water supply is from a tank, reservoir or from pressure pipe?

A2: The water supply comes from a pressure pipe.

Q3: What is the supply capacity? Is it limited?

A3: Supply capacity is limited with capacities of heating pump to be supplied.

Q4: Are there any specific environment regulations which need to be considered?

Q4: There are no specific environmental regulations to be considered.

This Clarification Note is dispatched simultaneously to all economic operators known to be interested and can be found at the same time uploaded under the relevant procurement notice on the OSCE's web-site at www.osce.org/procurement/tenders.

END